

Certificate of Product Approval

Certificate Number: 681g-(cl-1)

Issue: 05

Tyco Fire & Security GmbH

Victor Von Bruns-Strasse 21
 Neuhausen am Rheinfall
 Schaffhausen
 8212
 Switzerland



is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Alarm Warning Devices

802SB
 601SB
 601SBD
 602SB
 602SBD
 901SB
 FC430SB
 80DSB
 FC440SB

(refer to Appendix for details)

Standards

EN 54-3:2001 + A1:2002 + A2:2006

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd

P Halligan

Verifier

26 June 2018

Date of Issue

14 September 2006

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
 T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com
 LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 681g-(cl-1)

Issue: 05

Tyco Fire & Security GmbH

Certified Product	Description	LPCB Ref.No.
802SB	Analogue Addressable Type A Sounder Base Note: 1. Meets the requirements of EN 54-3 at the following tones: Fast Sweep Dutch Slow Whoop 500Hz to 1200Hz Temporal 3 880Hz	681g/01
FC430SB	Analogue Addressable Type A Sounder Base Note: 1. Meets the requirements of EN 54-3 at the following tones: Fast Sweep Dutch Slow Whoop 500Hz to 1200Hz Temporal 3 880Hz	681g/01
601SB	Conventional Type A Sounder Base Note: 1. Meets the requirements of EN 54-3 at the following tones: Temporal 3 880Hz Dutch Slow Whoop 500Hz to 1200Hz Continuous 880Hz	681g/02
601SBD	Conventional Type A Diode Sounder Base Note: 1. Meets the requirements of EN 54-3 at the following tones: Temporal 3 880Hz Dutch Slow Whoop 500Hz to 1200Hz Continuous 880Hz	681g/03
602SB	Conventional Type A Sounder Base Note: 1. Meets the requirements of EN 54-3 at the following tones: Temporal 3 880Hz Dutch Slow Whoop 500Hz to 1200Hz Continuous 880Hz	681g/04

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.


Signed for BRE Global Ltd

P Halligan
Verifier

26 June 2018
Date of Issue

14 September 2006
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com
LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 681g-(cl-1)

Issue: 05

Tyco Fire & Security GmbH

Certified Product	Description	LPCB Ref.No.
602SBD	Conventional Type A Diode Sounder Base Note: 1. Meets the requirements of EN 54-3 at the following tones: Temporal 3 880Hz Dutch Slow Whoop 500Hz to 1200Hz Continuous 880Hz	681g/05
901SB	Analogue Addressable Type A Sounder Base Note: 1. Meets the requirements of EN 54-3 at the following tones: Temporal 3 880Hz Dutch Slow Whoop 500Hz to 1200Hz Continuous 880Hz	681g/06
80DSB	Zettler Conventional Type A Indoor Detector Base Sounder, White Housing (576.080.001) Note: 1. Meets the requirements of EN 54-3 at the following tones: DIN 1Hz Sweep 1200Hz to 500Hz Dutch Slow Whoop 500Hz to 1200Hz Temporal 4 880Hz BS 1Hz Sweep 800Hz to 970Hz March Time Beep 880Hz 7Hz Fast Sweep 800Hz to 970Hz Temporal 3 880Hz 2 Tone 660Hz/880Hz Continuous 970Hz	681g/07
FC440DSB	FireClass Conventional Type A Indoor Detector Base Sounder, White Housing (576.440.001) Note: 1. Meets the requirements of EN 54-3 at the following tones: DIN 1Hz Sweep 1200Hz to 500Hz	681g/07

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.


Signed for BRE Global Ltd

P Halligan
Verifier

26 June 2018
Date of Issue

14 September 2006
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com
LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 681g-(cl-1)

Issue: 05

Tyco Fire & Security GmbH

Certified Product	Description	LPCB Ref.No.
	Dutch Slow Whoop 500Hz to 1200Hz Temporal 4 880Hz BS 1Hz Sweep 800Hz to 970Hz March Time Beep 880Hz 7Hz Fast Sweep 800Hz to 970Hz Temporal 3 880Hz 2 Tone 660Hz/880Hz Continuous 970Hz	

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.


Signed for BRE Global Ltd

P Halligan
Verifier

26 June 2018
Date of Issue

14 September 2006
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
 T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com
 LPCB is a Registered Trademark of the Building Research Establishment Ltd.

