

## Certificate of Product Approval

Certificate Number: 681bb-(cl-2)

Issue: 01

### Tyco Fire & Security GmbH

Victor Von bruns-Strasse 21,  
8212 Neuhausen am Rheinfall,  
Schaffhausen,  
Switzerland

is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

#### Products

##### Control and Indicating equipment

FC602S  
FC604S  
FC602S Lite Scandinavian  
FC604S Lite Scandinavian  
FC32AR  
FC32DR  
FC32AR-S  
FC32DR-S  
(refer to Appendix for details)

#### Standards

EN 54-2:1997 + A1:2006  
EN 54-4:1997 + A1:2002 + A2:2006

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

E Mattie-Suleiman

Verifier

28 May 2021

Date of Issue

28 May 2021

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre

## Appendix to Certificate No: 681bb-(cl-2)

Issue: 01

### Tyco Fire & Security GmbH

Certified Product	Description	LPCB Ref.No.
FC602S	<p>1-2 Loop Analogue Addressable Control and Indicating Equipment, Shallow Housing FireClass (557.200.650)</p> <p>Incorporating the following modules:</p> <p>PFI801-FC      Field Interface CUI              Colour User Interface BAW75T24      2.5 A PSU</p> <p>Incorporating the following optional modules:</p> <p>PNI800          Panel Network Interface FB800          Fuse Board</p> <p>Certified with the following options with requirements from EN54-2:</p> <p>7.8              Output to fire alarm device(s) 7.9.1            Output to fire alarm routing equipment 7.9.2            Alarm confirmation input from fire alarm routing equipment 7.10.1          Output to fire protection equipment- Output type A 7.10.2          Output to fire protection equipment- Output type B 7.10.3          Output to fire protection equipment- Output type C 7.10.4          Fault monitoring of fire protection equipment 7.11             Delays to outputs 7.12.1          Dependencies on more than one alarm signal- Type A 7.12.2          Dependencies on more than one alarm signal -Type B 7.12.3          Dependencies on more than one alarm signal -Type C</p>	681bb/01

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

E Mattie-Suleiman

Verifier

28 May 2021

Date of Issue

28 May 2021

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre

## Appendix to Certificate No: 681bb-(cl-2)

Issue: 01

### Tyco Fire & Security GmbH

Certified Product	Description	LPCB Ref.No.
	7.13 Alarm counter 8.3 Fault signals from points 8.9 Output to fault warning routing equipment 9.5 Disabling of each address point 10 Test condition 11 Output to standardised input/output interface  Notes: 1. Scope of approval does not include the operation of the network functionality 2. This product approval does not constitute compliance with the fire detection and alarm system requirements of EN54-13.	
FC604S	2-4 Loop Analogue Addressable Control and Indicating Equipment, Shallow Housing FireClass (557.200.651)  Incorporating the following modules: PFI801-FC Field Interface CUI Colour User Interface BAQ140T24 5 A PSU  Incorporating the following optional modules: PNI800 Profile Network Interface FB800 Fuse Board  Certified with the following options with requirements from EN54-2: 7.8 Output to fire alarm device(s)	681bb/02

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

E Mattie-Suleiman

Verifier

28 May 2021

Date of Issue

28 May 2021

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre

## Appendix to Certificate No: 681bb-(cl-2)

Issue: 01

### Tyco Fire & Security GmbH

Certified Product	Description	LPCB Ref.No.
	7.9.1 Output to fire alarm routing equipment 7.9.2 Alarm confirmation input from fire alarm routing equipment 7.10.1 Output to fire protection equipment- Output type A 7.10.2 Output to fire protection equipment- Output type B 7.10.3 Output to fire protection equipment- Output type C 7.10.4 Fault monitoring of fire protection equipment 7.11 Delays to outputs 7.12.1 Dependencies on more than one alarm signal- Type A 7.12.2 Dependencies on more than one alarm signal -Type B 7.12.3 Dependencies on more than one alarm signal -Type C 7.13 Alarm counter 8.3 Fault signals from points 8.9 Output to fault warning routing equipment 9.5 Disablement of each address point 10 Test condition 11 Output to standardised input/output interface  Notes: 1. Scope of approval does not include the operation of the network functionality 2. This product approval does not constitute compliance with the fire detection and alarm system requirements of EN54-13.	
FC602S Lite Scandinavian	1-2 Loop Analogue Addressable Control and Indicating Equipment, Shallow Housing FireClass Scandinavian (557.200.652)	681bb/06

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

E Mattie-Suleiman

Verifier

28 May 2021

Date of Issue

28 May 2021

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre

## Appendix to Certificate No: 681bb-(cl-2)

Issue: 01

### Tyco Fire & Security GmbH

Certified Product	Description	LPCB Ref.No.
	<p>Incorporating the following modules:</p> <p>PFI801-FC      Field Interface</p> <p>CUI              Colour User Interface</p> <p>BAW75T24      2.5 A PSU</p> <p>Incorporating the following optional units:</p> <p>PNI800          Panel Network Interface</p> <p>FB800          Fuse Board</p> <p>Certified with the following options with requirements from EN54-2:</p> <p>7.8              Output to fire alarm device(s)</p> <p>7.9.1            Output to fire alarm routing equipment</p> <p>7.9.2            Alarm confirmation input from fire alarm routing equipment</p> <p>7.10.1           Output to fire protection equipment- Output type A</p> <p>7.10.2           Output to fire protection equipment- Output type B</p> <p>7.10.3           Output to fire protection equipment- Output type C</p> <p>7.10.4           Fault monitoring of fire protection equipment</p> <p>7.11              Delays to outputs</p> <p>7.12.1           Dependencies on more than one alarm signal- Type A</p> <p>7.12.2           Dependencies on more than one alarm signal -Type B</p> <p>7.12.3           Dependencies on more than one alarm signal -Type C</p> <p>7.13              Alarm counter</p> <p>8.3              Fault signals from points</p> <p>8.9              Output to fault warning routing equipment</p> <p>9.5              Disablement of each address point</p>	

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

E Mattie-Suleiman

Verifier

28 May 2021

Date of Issue

28 May 2021

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre

## Appendix to Certificate No: 681bb-(cl-2)

Issue: 01

### Tyco Fire & Security GmbH

Certified Product	Description	LPCB Ref.No.
	10 Test condition 11 Output to standardised input/output interface  Notes: 1. Scope of approval does not include the operation of the network functionality 2. This product approval does not constitute compliance with the fire detection and alarm system requirements of EN54-13.	
FC604S Lite Scandinavian	2-4 Loop Analogue Addressable Control and Indicating Equipment, Shallow Housing FireClass Scandinavian (557.200.653)  Incorporating the following Modules: PFI800-FC Field Interface CUI Colour User Interface BAQ140T24 5 A PSU  Incorporating the following optional units: PNI800 Panel Network Interface FB800 Fuse Board  Certified with the following options with requirements from EN54-2: 7.8 Output to fire alarm device(s) 7.9.1 Output to fire alarm routing equipment 7.9.2 Alarm confirmation input from fire alarm routing equipment 7.10.1 Output to fire protection equipment- Output type A 7.10.2 Output to fire protection equipment- Output type B	681bb/07

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

E Mattie-Suleiman

Verifier

28 May 2021

Date of Issue

28 May 2021

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre

## Appendix to Certificate No: 681bb-(cl-2)

Issue: 01

### Tyco Fire & Security GmbH

Certified Product	Description	LPCB Ref.No.
	7.10.3 Output to fire protection equipment- Output type C 7.10.4 Fault monitoring of fire protection equipment 7.11 Delays to outputs 7.12.1 Dependencies on more than one alarm signal- Type A 7.12.2 Dependencies on more than one alarm signal -Type B 7.12.3 Dependencies on more than one alarm signal -Type C 7.13 Alarm counter 8.3 Fault signals from points 8.9 Output to fault warning routing equipment 9.5 Disablement of each address point 10 Test condition 11 Output to standardised input/output interface  Notes: 1. Scope of approval does not include the operation of the network functionality 2. This product approval does not constitute compliance with the fire detection and alarm system requirements of EN54-13.	
FC32AR	32 Zone AC Repeater, FireClass 557.202.914  Incorporating the following modules: CUI-R Repeater Colour User Interface PMM800 Power Monitor Module BAW75T24 Power Supply Unit, 2.5 A	681bb/R01

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

E Mattie-Suleiman

Verifier

28 May 2021

Date of Issue

28 May 2021

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre

## Appendix to Certificate No: 681bb-(cl-2)

Issue: 01

### Tyco Fire & Security GmbH

Certified Product	Description	LPCB Ref.No.
	Note: Approved for use with the FC602S, FC604S, FC602S Lite Scandinavian and FC604S Lite Scandinavian	
FC32DR	32 Zone DC Repeater, FireClass 557.202.915  Incorporating the following modules: CUI-R Repeater Colour User Interface  Note: Approved for use with the FC602S, FC604S, FC602S Lite Scandinavian and FC604S Lite Scandinavian	681bb/R02
FC32AR-S	32 Zone AC Repeater, FireClass Scandinavian (557.200.656)  Incorporating the following modules: CUI-R Repeater Colour User Interface PMM800 Power Monitor Module BAW75T24 Power Supply Unit, 2.5 A  Note: Approved for use with the FC602S Lite Scandinavian and FC604S Lite Scandinavian	681bb/R05
FC32DR-S	32 Zone DC Repeater, FireClass Scandinavian (557.200.657)  Incorporating the following modules: CUI-R Repeater Colour User Interface  Note: Approved for use with the FC602S Lite Scandinavian and FC604S Lite Scandinavian	681bb/R06

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

E Mattie-Suleiman

Verifier

28 May 2021

Date of Issue

28 May 2021

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



**bre**